



# Certificate of Compliance

**Certificate:** 1370479 (LR 26243-18)

**Master Contract:** 160736

**Project:** 1370479

**Date Issued:** October 10, 2002


**Issued to:** O'BRIEN CORPORATION  
1900 Crystal Industrial Ct.  
St. Louis, MO 63114  
USA  
**Attention:** Mike Pellegrini

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:**   
Ezio Migliozi

**Authorized by:** Nick Alfano  
Operations Manager



## PRODUCTS

**CLASS 2878 02 - HEATERS - Miscellaneous - For Hazardous Locations**

Class I, Div. 1 and 2, Groups B, C and D; Class I, Zone 1 and 2, Groups IIB + H<sub>2</sub>:

Instrument Heater Series CW918, rated 277V ac max, 200W max.

**Note:** Series Cat No CW918 may be followed with suffix number to denote operating temperature, wattage and voltage ratings.



**Certificate:** 1370479 (LR 26243-18)

**Master Contract:** 160736

**Project:** 1370479

**Date:** October 10, 2002

---

**APPLICABLE REQUIREMENTS**

CSA Std C22.2 No. 30-M1986-Explosion-Proof Enclosures for Use in Class I Hazardous Locations  
CSA Std C22.2 No. 46-M1988-Electric Air-Heaters

**MARKINGS**

- Submitter's name.
- Catalogue number designation.
- Hazardous location designation.
- Maximum operating temperature or temperature code.
- Complete electrical ratings.
- Caution: "RE USE IN HAZARDOUS LOCATIONS".
- CSA Monogram.