

Certificate of Compliance

Certificate: 1370479 (LR 26243-18)

Master Contract: 160736

Project:

1370479

Date Issued: October 10, 2002

Issued to:

O'BRIEN CORPORATION 1900 Crystal Industrial Ct. St. Louis, MO 63114

USA

Attention: Mike Pellegrini

The products listed below are eligible to bear the CSA Mark shown



Issued by:

Ezio Migliozi

Authorized by: Nick Alfano

Operations Manager

PRODUCTS

CLASS 2878 02 - HEATERS - Miscellaneous - For Hazardous Locations

Class I, Div. 1 and 2, Groups B, C and D; Class I, Zone 1 and 2, Groups IIB + H₂:

Instrument Heater Series CW918, rated 277V ac max, 200W max.

<u>Note</u>: Series Cat No CW918 may be followed with suffix number to denote operating temperature, wattage and voltage ratings.



Certificate: 1370479 (LR 26243-18)

Project: 1370479

Master Contract: 160736

Date: October 10, 2002

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 30-M1986-Explosion-Proof Enclosures for Use in Class I Hazardous Locations CSA Std C22.2 No. 46-M1988-Electric Air-Heaters

MARKINGS

- Submittor's name.
- Catalogue number designation.
- Hazardous location designation.
- Maximum operating temperature or temperature code.
- Complete electrical ratings.
- Caution: "RE USE IN HAZARDOUS LOCATIONS".
- CSA Monogram.